

Michigan Department of Environmental Quality Analytical Testing Report

Report Date: 11/15/2024 10:09
 Client: EGLE-RRD-LANSING
 Attention: Mike Jury
 Project Name: MPART-CADILLAC INDUSTRIAL PARK

					Address 1	Address 2	Address 3	Address 4	Address 5	Address 6	Address 7		
Sample Number			Michigan Safe Drinking Water Act MCL ^[1] and Groundwater Cleanup Std		National Primary Drinking Water Regulation MCL ^[2]		2410342-02	2410342-03	2410342-04	2410342-05	2410342-06	2410342-07	2410342-08
Sample ID							WT2410301004GSC	WT2410301115GSC	WT2410301145GSC	WT2410301210GSC	WT2410301240GSC	WT2410301310GSC	WT2410301335GSC
Sample Depth													
Date Collected							10/30/2024	10/30/2024	10/30/2024	10/30/2024	10/30/2024	10/30/2024	10/30/2024
Date Received							10/31/2024	10/31/2024	10/31/2024	10/31/2024	10/31/2024	10/31/2024	10/31/2024
Analyte	Units	Method											
11Cl-PF3OUdS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
4:2FTS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
6:2FTS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
8:2FTS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
9Cl-PF3ONS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
ADONA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
HFPO-DA	ppt	533	370	10	<2	<2	<2	<2	<2	<2	<2		
NFDHA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFBA	ppt	533	NA	NA	5	3	2	<2	<2	4	2		
PFBS	ppt	533	420	NA	11	2	6	<2	<2	2	7		
PFDA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFDaA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFEESA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFHpA	ppt	533	NA	NA	<2	<2	<2	<2	<2	3	<2		
PFHpS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFHxA	ppt	533	400,000	NA	<2	2	3	4	<2	5	<2		
PFHxS	ppt	533	51	10	4	3	2	<2	<2	2	2		
PFMBA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFMPA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFNA	ppt	533	6	10	<2	<2	<2	<2	<2	<2	<2		
PFOA	ppt	533	8	4.0	4	5	4	6	<2	12	2		
PFOS	ppt	533	16	4.0	<2	3	<2	6	<2	<2	<2		
PFPeA	ppt	533	NA	NA	<2	<2	3	4	<2	3	<2		
PFPeS	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		
PFUnA	ppt	533	NA	NA	<2	<2	<2	<2	<2	<2	<2		

Grey indicates contaminant was detected.

Yellow indicates contaminant exceeds Michigan Drinking Water Criteria

"NA" means a criterion or value is not available or, in the case of background, not applicable

Note that sample number 2410342-01 is a field blank

[1] Maximum Contaminant Level (MCL) is the maximum amount of a contaminant allowed in drinking water. Applies only to public drinking water supplies covered under the Michigan Safe Drinking Water Act. Private residential wells are not regulated under the Michigan Safe Drinking Water Act, but Michigan uses the MCLs along with other factors when evaluating private residential well results.

[2] Compliance with MCLs is determined by running annual averages at the sampling point.

Address 8	Address 9	Address 10	Address 11	Address 12	Address 13
2410342-09	2410342-10	2410342-11	2410342-12	2410342-13	2410342-14
WT2410301525GSC	WT2410301635GSC	WT2410301645GSC	WT2410301700GSC	WT2410301715GSC	WT2410301730GSC
10/30/2024	10/30/2024	10/30/2024	10/30/2024	10/30/2024	10/30/2024
10/31/2024	10/31/2024	10/31/2024	10/31/2024	10/31/2024	10/31/2024
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	3	<2	2	4
2	<2	2	<2	9	6
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	3
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	4	6
<2	<2	2	<2	3	17
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2
2	<2	2	3	7	13
<2	<2	2	<2	<2	<2
<2	<2	<2	<2	3	2
<2	<2	<2	<2	<2	<2
<2	<2	<2	<2	<2	<2