					Address 1	Address 2	Address 3	Address 4
Sample Number								
Sample ID			Michigan Safe Drinking Water Act MCL ^[1] and Groundwater	National Primary Drinking Water Regulation	Resident	Resident Dup		
Sample Depth								
Date Collected					9/30/2024	9/30/2024		
Date Analyzed					10/17/2024	10/17/2024		
Analyte	Units	Method	Cleanup Std	MCL ^[2]				
11Cl-PF3OUdS	ppt	533	NA	NA	<2	<2		
4:2FTS	ppt	533	NA	NA	<2	<2		
6:2FTS	ppt	533	NA	NA	<2	<2		
8:2FTS	ppt	533	NA	NA	<2	<2		
9CI-PF3ONS	ppt	533	NA	NA	<2	<2		
ADONA	ppt	533	NA	NA	<2	<2		
HFPO-DA	ppt	533	370	10	<2	<2		
NFDHA	ppt	533	NA	NA	<2	<2		
PFBA	ppt	533	NA	NA	11.3	11.7		
PFBS	ppt	533	420	NA	39.8	40.6		
PFDA	ppt	533	NA	NA	<2	<2		
PFDoA	ppt	533	NA	NA	<2	<2		
PFEESA	ppt	533	NA	NA	<2	<2		
PFHpA	ppt	533	NA	NA	<2	<2		
PFHpS	ppt	533	NA	NA	<2	<2		
PFHxA	ppt	533	400,000	NA	<2	<2		
PFHxS	ppt	533	51	10	<2	<2		
PFMBA	ppt	533	NA	NA	<2	<2		
PFMPA	ppt	533	NA	NA	<2	<2		
PFNA	ppt	533	6	10	<2	<2		
PFOA	ppt	533	8	4.0	<2	5.0		
PFOS	ppt	533	16	4.0	5.4	20.6		
PFPeA	ppt	533	NA	NA	<2	<2		
PFPeS	ppt	533	NA	NA	<2	<2		
PFUnA	ppt	533	NA	NA	<2	<2		

Exceeds Nat'l Primary Drinking Water MCL

Exceeds Nat'l Primary Drinking Water MCL and/or MI SDWA MCL

"NA" means a criterion or value is not available

- [1] Maximum Contaminant Level (MCL) is the maximum amount of a contaminant allowed in drinking water. Applies only to public drinking water supplies covered under the Michigan Safe Drinking Water Act. Private residential wells are not regulated under the Michigan Safe Drinking Water Act, but Michigan uses the MCLs along with other factors when evaluating private residential well results.
- [2] Compliance with MCLs is determined by running annual averages at the sampling point.